


KL 17

SAMPLE COOLER
 type SCV
 pressure series PN16, PN40, PN100



Model pressure PN	Closing armature type A	DN	PN	Count ks
16	Clock globe	1/2"	16	1
40	Clock globe	10	63	2
100	V 10 151 4100	10	100	2

The sample cooler is used for cooling of samples taken from feeding water, saturated and preheated steam and other liquids in the energetics.

The internal coil of the sample cooler is typically delivered in stainless steel (material class 17), external housing, welded-on pieces and a discharge funnel are supplied made of material class 11 or stainless steel (material class 17).

Dimensions in the table are informative.

SEA CZ, a.s. zapsána v OR u Krajského obchodního soudu v Brně, oddíl B, vložka 3214

Výpusta 400, 760 01 Zlín

tel. 577 220 351-4

fax 577 220 357

e-mail: seacz-zl@seacz.cz

KB Zlín, č.ú. 27-1922340217/0100

IČO 25588664

www.seacz.cz

DIČ 303-25588664

Tyršova 469, 280 00 Kolín 2

tel. 321 729 249

fax 321 722 809

e-mail: seacz-kol@seacz.cz

KB Kolín, č.ú. 27-4397410267/0100